



CONSERVATION ENHANCEMENT ACTIVITY

E533C

CONSERVATION STEWARDSHIP PROGRAM

Install VFDs on pumping plants

CONSERVATION PRACTICE: 533 - Pumping Plant

APPLICABLE LAND USE: Crop (Annual & Mixed); Crop (Perennial); Pasture; Associated Ag Land; Farmstead

RESOURCE CONCERN: Energy

ENHANCEMENT LIFE SPAN: 1 year

Enhancement Description

Install Variable Frequency Drive(s) (VFD) on Pumping Plant with the correct sensors, on all pumps as indicated in the evaluation.

Criteria

- Implement recommendations for components from a pumping plant evaluation where the FVD is feasible, reduces energy use, and the existing or new electric drive unit will support the VFD.
- The replacement or retrofit system and related components or devices meet or exceed currently applicable federal, state, and local standards and guidelines.
- Components of this enhancement will meet the NRCS Conservation Practice Standard Pumping Plant (Code 533).



Documentation and Implementation Requirements

**CONSERVATION
STEWARDSHIP
PROGRAM**

Participant will:

Prior to implementation:

- Review pumping plant evaluation, season of use, existing pump motor needs, and current operation.
- Evaluate site specific energy alternatives and net benefit of the Variable Frequency Drive(s).
- Ensure that energy utility provider has reviewed and approved location of installation on pump motor, including needs for electrical harmonic filter.
- Obtain written documentation of utility approval for site with requirements for installation.

During implementation

- Ensure installation meets federal National Electrical Code and any local or state codes.

After implementation

- Provide documentation of installation including first season energy use for comparison to prior years to NRCS for review to verify implementation of the enhancement.
- Monitor and maintain system for the life span of the practice (10 years).

NRCS will:

Prior to implementation

- Provide and explain NRCS Conservation Practice Standard Pumping Plant (Code 533) as it relates to implementing this enhancement.
- As needed, provide additional technical assistance to the participant as requested.
- Review with the participant the costs and benefits of the installation of Variable Frequency Drive(s).
- Develop written specifications describing site specific details of installation, including:
 - The replacement or retrofit system and/or related components or devices.
 - Baseline system energy usage and potential energy savings from the implementation of this enhancement.
 - Plan view showing the location of the measures in relation to other structures or natural features, where appropriate.
 - Electrical wiring that meets the requirements of the National Electrical Code.
 - Operation and maintenance plan that is consistent with the purpose(s) of this practice, its intended life, and safety requirements.



CONSERVATION STEWARDSHIP PROGRAM

After implementation

- Verify energy savings based on system efficiency before and after implementation of the enhancement

NRCS Documentation Review:

I have reviewed all required participant documentation and have determined the participant has implemented the enhancement and met all criteria and requirements.

Participant Name _____

Contract Number _____

Total Amount Applied _____

Fiscal Year Completed _____

NRCS Technical Adequacy Signature

Date